

UL Online Certifications Directory

UTHV.S24018 Heat-actuated Devices for Special Application

[Page Bottom](#)

Heat-actuated Devices for Special Application

[See General Information for Heat-actuated Devices for Special Application](#)

SAFE FIRE DETECTION INC

S24018

5915 STOCKBRIDGE DR
MONROE, NC 28110 USA

Line type, fixed temperature heat detectors for indoor/outdoor use, Model TC155, temperature ratings are 68° C (155° F); Model TC172 temperature ratings are 78° C (172° F); Model TC190, temperature ratings are 88° C (190° F); Model TC221, temperature ratings are 105° C (221° F).

Intended for equipment protection applications.

[Last Updated](#) on 2006-03-07

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2006 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2006 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

