

# EVPU



## CERTIFICATE No. 00061/101/1/2008 of March 5, 2008

EVPU a.s., Nová Dubnica, authorized for Certification issue this Certificate.


1. Product ( type ) : **Fire Alarm Control Panel  
EOLO**
2. Specification : **230V~, 50Hz, 690mA / class I**
3. Applicant : **TELEDATA s.r.l.  
Via Giulietti 8, 20 132 Milano, Italy**
4. Manufacturer : **TELEDATA s.r.l.  
Via Giulietti 8, 20 132 Milano, Italy**

This Certificate confirms the compliance of features of mentioned product type with technical requirements in following technical and legal decrees:

**EN 60950-1: 2006**  
**EN 54-2: 1997 + AC: 1999 + A1: 2006**  
**EN 54-4: 1997 + AC: 1999 + A1: 2002 + A2: 2006**

Results of tests and findings on the conformity of features of mentioned product type are stated in Final report No. **00136/2008/C** of March 5, 2008.

Validity of this certificate is limited for the period from : **March 5, 2008**  
within : **March 4, 2011**



  
**Karol Gilamoš**

Any significant changes in the design or construction of the products, the quality system and amendments of the technical and legal decrees reference above may tender this Certificate invalid. The product liability rests with the manufacturer or his representative.

014486

EVPU a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, [www.evpu.sk](http://www.evpu.sk)