


# EVPÜ<sup>®</sup>

## CERTIFICATE

No. 00031/101/1/2013  
on 15. marec 2013



Applicant  
**TELEDATA s.r.l**  
Via Giulietti, 8, 20132 Milano, Italy

Identification code  
**00001116**

Manufacturer  
**TELEDATA s.r.l**  
Via Giulietti 8, 20132 Milano, Italy

Product  
**Fire alarm control panel**

Type  
**EOLO**

Specifications  
**230V~, 50Hz, 690 mA / class I**

The sample meets the essential safety requirements of the following Directives of EP and Council transposed into "Slovak government decrees" as amended:

**LVD Directive 2006/95/EC - GD SR 308/2004 Coll. of Laws,**  
**EMC Directive 2004/108/EC - GD SR 194/2005 Coll. of Laws**

A sample of the product was tested and found to be in conformity with following standards and / or technical specifications applied:

**EN 60950-1: 2006 + A11: 2009 + A1: 2010 + A12: 2011**  
**EN 55022: 2010**  
**EN 61000-3-2: 2006 + A1: 2009 + A2: 2009**  
**EN 61000-3-3: 2008**  
**EN 50130-4: 2011**

Results of tests and examinations of the conformity of features of mentioned product type are stated in Final report No. 00056/2013/C on March 14th, 2013.

Certificate confirms that the equipment complies with the Essentials requirements and purpose of use mentioned in Directives of EP and Council / standards.

Certificate is valid until : **March 13th, 2016**

Marek H u d a k



Marking may only be used if all relevant and effective Directives of EP and Council are complied with.

Any significant changes in the design or construction of the products, the quality system and amendments of the technical and legal decrees reference above may tender this Certificate invalid. The product liability rests with the manufacturer or his representative.

045491

EVPÜ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, [www.evpu.sk](http://www.evpu.sk)

Page 1 / 1 FCO 64-07 rev.4