



EVPÜ[®]

CERTIFICATE

No. 00164/101/1/2014
on September 24th, 2014

Applicant
TELEDATA s.r.l
Via Giulietti, 8, 20132 Milano, Italy

Manufacturer
TELEDATA s.r.l
Via Giulietti 8, 20132 Milano, Italy

Product
Fire alarm control panel

Type
OLYMPIA

Specifications
230 V~, 50 Hz, 690 mA, class I

The sample meets the essential safety requirements of the following Directives of EP and Council transposed into "Slovak government decrees" as amended:

LVD Directive 2006/95/EC - GD SR 308/2004 Coll. of Laws,
EMC Directive 2004/108/EC - GD SR 194/2005 Coll. of Laws


A sample of the product was tested and found to be in conformity with following standards and / or technical specifications applied:

EN 60950-1: 2006 + A11: 2009 + A1: 2010 + A12: 2011 + A2: 2013
EN 55022: 2010
EN 50130-4: 2011
EN 61000-3-2: 2006 + A1: 2009 + A2: 2009
EN 61000-3-3: 2013

Results of tests and examinations of the conformity of features of mentioned product type are stated in Final report No. 00376/2014/C on September 24th, 2014.

Certificate confirms that the equipment complies with the Essentials requirements and purpose of use mentioned in Directives of EP and Council / standards.

Certificate is valid until : **September 23rd, 2017**



Marking may only be used if all relevant and effective Directives of EP and Council are complied with.

Any significant changes in the design or construction of the products, the quality system and amendments of the technical and legal decrees reference above may tender this Certificate invalid. The product liability rests with the manufacturer or his representative.

EVPÜ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk

051915

Page 1 / 1 FCO 64-07 rev.4