

Certificate of Product Approval

Certificate Number: 1154c

Issue: 03

ATEIS Middle East FZCO

LIU 11 Dubai Silicon Oasis
Post Box 293640
Dubai
United Arab Emirates



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Multi Criteria Detectors

VELOX 40920
VELOX 40920-8
V200
(refer to Appendix for details)

Standards

EN 54-5:2000 + A1:2002
EN 54-7:2000 + A1:2002 + A2:2006
EN 54-17:2005
CEA 4021:2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

31 May 2017

Date of Issue

16 June 2014

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1154c

Issue: 03

ATEIS Middle East FZCO

Certified Product	Description	LPCB Ref.No.
VELOX 40920	<p>Analogue Addressable Class P Heat and Photoelectric Smoke Multi-sensor Detector with Short Circuit Isolator (40900, 40900-S, 40900-DP and 40900-DPS bases)</p> <p>Notes:</p> <p>1. Meets the requirements of EN 54-5 for (Class A1) & EN 54-7 at the following settings: Multi Criteria Level 1 (most sensitive) – Thermally enhanced smoke detection with class A1 heat response Multi Criteria Level 2 – Thermally enhanced smoke detection with Class A1 heat response Multi Criteria Level 3 – Thermally enhanced smoke detection with Class A1 heat response Multi Criteria level 4 (least sensitive) – Thermally enhanced smoke detection with Class A1 heat response</p> <p>2. Meets the requirements of EN 54-5 (class A1R) at the following settings: Class A1R heat only response</p> <p>3. Meets the requirements of EN 54-7 at the following settings: Optical only level 1 – High Optical only level 2 Optical only level 3 Optical only level 4 – Low</p>	1154c/01
V200	<p>Analogue Addressable Class P Heat and Photoelectric Smoke Multi-sensor Detector with Short Circuit Isolator (VB100, VB100S, VDBS100 and VDBS100S bases)</p> <p>Notes:</p> <p>1. Meets the requirements of EN 54-5 for (Class A1) & EN 54-7 at the following settings: Multi Criteria Level 1 (most sensitive) – Thermally enhanced smoke detection with class A1 heat response Multi Criteria Level 2 – Thermally enhanced smoke detection with Class A1 heat response Multi Criteria Level 3 – Thermally enhanced smoke detection with Class A1 heat response</p>	1154c/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
 Verifier

31 May 2017
 Date of Issue

16 June 2014
 Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
 LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1154c

Issue: 03

ATEIS Middle East FZCO

Certified Product	Description	LPCB Ref.No.
	Multi Criteria level 4 (least sensitive) – Thermally enhanced smoke detection with Class A1 heat response 2. Meets the requirements of EN 54-5 (class A1R) at the following settings: Class A1R heat only response 3. Meets the requirements of EN 54-7 at the following settings: Optical only level 1 – High Optical only level 2 Optical only level 3 Optical only level 4 – Low	
VELOX 40920-8	Analogue Addressable Class P Heat and Photoelectric Smoke Multi-sensor Detector with Short Circuit Isolator (40900, 40900-S, 40900-DP and 40900-DPS bases) Notes: 1. Meets the requirements of EN 54-5 for (Class A1) & EN 54-7 at the following settings: Multi Criteria Level 1 (most sensitive) – Thermally enhanced smoke detection with class A1 heat response Multi Criteria Level 2 – Thermally enhanced smoke detection with Class A1 heat response Multi Criteria Level 3 – Thermally enhanced smoke detection with Class A1 heat response Multi Criteria level 4 (least sensitive) – Thermally enhanced smoke detection with Class A1 heat response 2. Meets the requirements of EN 54-5 (class A1R) at the following settings: Class A1R heat only response 3. Meets the requirements of EN 54-7 at the following settings: Optical only level 1 – High Optical only level 2 Optical only level 3 Optical only level 4 - Low	1154c/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

31 May 2017
Date of Issue

16 June 2014
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1154c

Issue: 03

ATEIS Middle East FZCO

Bases:

- 40900 Velox adaptor base
- 40900-S Velox adaptor base with shorting clip
- 40900-DP Velox deep adaptor base
- 40900-DPS Velox deep adaptor base with shorting clip
- VB100 Velox adaptor base
- VB100S Velox adaptor base with shorting clip
- VDBS100 Velox deep adaptor base
- VDBS100S Velox deep adaptor base with shorting clip

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

31 May 2017
Date of Issue

16 June 2014
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1154c

Issue: 03

ATEIS Middle East FZCO

Alternative Model No./Label

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
1154c/02	VELOX 40920-8	SF5200	Teledata S.r.l	1154c-(cl-1)

Bases

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
1154	40900	BS5000	Teledata S.r.l	1154c-(cl-1)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

31 May 2017
Date of Issue

16 June 2014
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.


